

Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*
R 50726293 0001

Berichtsnummer *Report No.:*
CN26VCAW 001

Genehmigungsinhaber *License Holder:*
Zhejiang Tengen Electric Co., Ltd.
Sulv Industrial Area,
Liushi Town, Yueqing City,
325604 Zhejiang
P.R. China

Fertigungsstätte *Manufacturing Site:*
Zhejiang Tengen Electric Co., Ltd.
(Yueqing Economic
Development Zone Branch)
No.288 Central Avenue
Development Zone, Yueqing City,
325604 Zhejiang
P.R. China

Prüfzeichen *Test Mark:*



Geprüft nach *Tested according to:*
EN IEC 60947-2:2025

Geräteidentifikation

Product Identification

Produkt: Moulded case circuit breaker
Product: (Moulded case circuit breaker)

Modell: Modelle sind auf nächste(r) Seite(n) gelistet
Type: *Type designation(s) are listed on the next page(s)*

Technische Daten: Technische Daten auf nächste(r) Seite(n) gelistet
Technical Data: *Technical Data is listed on the next page(s)*

Gültig ab: 2026-04-30
Valid from:

Zertifizierungsstelle:
Certification body:

Ausstellungsdatum: 2026-04-30
Date of issue:

Wencai Zhang

Wencai Zhang



Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
<http://www.tuv.com/safety> E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

Zertifikat Certificate

Zertifikatsnummer Certificate No.:

R 50726293 0001

Berichtsnummer Report No.:

CN26VCAW 001

Produkt Product: Moulded case circuit breaker
(Moulded case circuit breaker)

Modell Type: **Bezeichnung Designation:**
TGM3E-125xy/abcdefg (x=C, N, L, S, M, H; y=Blank, Z, P; a=3, 4; b=3;
c=00, 08, 10, 20, 21, 30, 40, 41, 50, 51, 52, 70, 71, 18, 38, 48, 28,
78, 55, 58, 47, 56, 68, 77; d=Blank, 2; e=B, C; f=Blank, III; g=Blank,
E1, E2, E3, E4, E5)

Type of Release : Electronic
 Rated Current of Electronic Release : 32A(12.5A~32A adjustable+OFF),
 63A (25A~63A adjustable+OFF),
 100A(40A~100A adjustable+OFF),
 125A(50A~125A adjustable+OFF)
 Rated Instantaneous Short-circuit Current Setting(Ii) : (3~14)Ir adjustable+OFF;
 (4~12)Ir adjustable+OFF
 (g=E4, E5)
 Conventional Free Air Thermal Current : Same as In
 Number of Poles : 3P, 4P
 Tripping Class : 10A, 10, 20, 30
 Rated Operational Voltage : AC380/400/415V
 Rated Frequency : 50/60Hz
 Rated Impulse Withstand Voltage : 8kV
 Rated Insulation Voltage : 1000V
 Breaking Capacity Level : C, N, L, S, M, H
 Rated Short-circuit Withstand Current : 1.5kA/1s
 Suitability for Isolation : Yes
 Method of Installation : Fixed, Plug-in
 Rated Ultimate Short-circuit Breaking Capacity:
 36kA(x=C); 50kA(x=N); 50kA(x=L); 70kA(x=S); 70kA(x=M); 100kA(x=H)
 Rated Service Short-circuit Breaking Capacity :
 36kA(x=C); 40kA(x=N); 50kA(x=L); 50kA(x=S); 70kA(x=M); 70kA(x=H)
 Shunt Release(MX3M12) :
 Us: AC220/230/240V, AC380/400/415V, 50/60Hz; DC110V, DC220V, DC24V;
 Ui: 690V; Uimp: 4kV
 Auxiliary(OF3M12) and Alarm(SD3M12) Contacts:
 AC-15: AC380/400/415V/0.3A; 50/60Hz; DC-13: DC110/220/250V/0.15A;
 1N01NC; 2N02NC; Ui:690V; Uimp:4kV; Ith=5A
 Electronic Accessories in Compliance with Annex N :
 Undervoltage Release(MN3M12) :
 Us: AC220/230/240V, AC380/400/415V; 50/60Hz; Ui: 800V; Uimp: 4kV
 Motor-operators(CD3M12-a-x(a=3P, 4P; x=A1, A2, D1)):
 Us: AC/DC110/220/230/240V(x=A1), AC380/400/415V(x=A2), DC24V(x=D1);
 Ui: 690V; Uimp: 4kV
 Overload Alarm Module :
 Us: AC220/230/240V, AC380/400/415V, 50/60Hz; DC24V

ANLAGE (Appendix): 1